

Cathy A. Leonard

From: Chris Martin
Sent: Monday, November 01, 2010 11:17 AM
To: Cathy A. Leonard
Subject: FW: Trompke gravel pit application comments

-----Original Message-----

From: W.A. Shaheen [mailto:billshaheen@analytical-engineering.com]
Sent: Tuesday, June 29, 2010 10:22 AM
To: Chris Martin; CONCOM; Cathy A. Leonard
Cc: 'Kimberly Masiuk'
Subject: Re: Trompke gravel pit application comments

Hi Chris,

Here are some ConCom comments regarding the Trompke Gravel Pit application.....

Please note the second page is missing from the application.....

You may wish to consult with CC further on this matter as there seems to be numerous omissions from the submittal as presented to us.....

Please advise as to the Board's wishes.

Thanks,

Bill Shaheen

From: Kimberly Masiuk [mailto:kmm@abuilders.com]
Sent: Monday, June 28, 2010 8:42 PM
To: W.A. Shaheen
Subject: trompke

I will scan and email the gravel permit report when I get in tomorrow morning. Here are my comments:

- I didn't have any site plan to look at but we should have one on record and it should be stamped. I would also have the selectmen update the plan annually to show what has been excavated.
- Who did the test pits to verify groundwater elevation, a DEP certified soil evaluator? There is no estimated groundwater elevation on here. We need to see groundwater elevation to compare to lowest excavation elevation.
- We should have a letter from a wetland consultant stating that there are no areas within the proposed limit of work is within the Conservation Commission's jurisdiction. A DEP wetlands map should also be included.

- The copy you gave me is missing the second page with items b. through k. so I couldn't comment on those things.
- The EPA NPDES SWPPP - There are no signatures on anything, there are no project timelines, no discussion about how much earth will be open at one time and what efforts will be made to limit that, there is no discussion about pollution prevention methods like park equipment here and if there is a spill do x,y,z to prevent it from entering the ground and reaching groundwater.
- Select Board should review the following and add stipulations to the permit.

Permit Limitations / Special Conditions for Permit

	Method of removal.
	Type and location of temporary structures.
	Hours of operation.
	Rules for transporting the material through Town.
	Area and depth of excavation.
	Distance of excavation to street and lot lines.
	Steepness of slopes excavated.
	Re-establishment of ground levels and grades.
	Provision for temporary and permanent drainage.
	Disposition of boulders and tree stumps.
	Fencing and signs necessary for public safety.
	Replacement with loam or topsoils of four inches or pre-existing topsoil condition, whichever is greater, over the area of removal.
	Planting of the area to suitable cover, including trees.
	Provision for proper access and egress to and from site to highway or local streets.
	Inspection of the premises at any time by the Board or its representative.
	Cash, certified check, surety bond or other security in a sum sufficient to insure compliance with the conditions stipulated in such permit.
	Provide a pollution prevention plan.
	Other:

Thank you,

Kimberly M. Masiuk