

The Granby Board of Health on April 26, 1976, voted to clarify its regulations which were adopted starting January 1, 1976 regarding the State Sanitary Code, Article 11, Regulation 14.1e.

Section 14.1e (1) shall read: Minimum area for leaching trench or seepage pit is 1.0 square foot per gallon (Bottom of trench only).

Section 14.1e (2) shall read: Minimum area for leaching bed is 2.0 Square feet per gallon, and leaching bed areas (bottom only) will Contain at least twice the area determined for trenches using Previously adopted values.

#### GRANBY BOARD OF HEALTH

Francis E. DeWitt  
Joseph V. Choquette  
Richard G. Bombardier